VILLAGE OF GILBERTS

RESOLUTION 15-2021

A RESOLUTION AUTHORIZING APPROVAL OF AGREEMENTS WITH MIDWEST POWER VAC AND WATER SURPLUS FOR THE REMOVAL AND REPLACEMENT OF WATER SOFTENER MEDIA IN AN AGGREGATE AMOUNT NOT TO EXCEED \$40,000

WHEREAS, the Village of Gilberts ("Village") has a Public Works Department which maintains Village streets and other Village infrastructure, which includes the Village's waterworks system; and

WHEREAS, the Village currently uses water softeners in the water production process; and

WHEREAS, the softener filtration media requires replacement; and

WHEREAS, adequate funds were included in the FY2022 Budget for the removal and replacement of the softener media for one of the three softeners as part of a multi-year replacement program; and

WHEREAS, the Public Works Department obtained multiple quotes for the removal and replacement of the softener medium with the low quote for removal being provided by Midwest Power Vac and for replacement by Water Surplus.

THEREFORE, BE IT RESOLVED BY THE PRESIDENT AND BOARD OF TRUSTEES OF THE VILLAGE OF GILBERTS, ILLINOIS, as follows:

- Section 1. Recitals. The recitals set forth above are hereby incorporated into and made a part of this Resolution as though set forth in this Section 1.
- <u>Section 2</u>. <u>Approval; Authorization</u>. The Village Board of Trustees hereby authorizes the Village Administrator to execute agreements and other necessary documents with Midwest Power Vac and Water Surplus for the removal and replacement of water softener media in an aggregate amount not-to-exceed \$40,000.
- **Section 3. Waiver of Competitive Bidding.** To the extent any competitive bidding requirements apply to the agreements with Midwest Power Vac and Water Surplus, such competitive bidding requirements are hereby waived pursuant to Section 8-9-1 of the Illinois Municipal Code (65 ILCS 5/8-9-1).
 - **Section 4. Effective Date.** This Resolution shall be in full force and effect after its

approval in the manner provided by law.

PASSED BY VOT County, Illinois, this			USTEES of the	e Village of Gil	berts, Kane
Trustee Dave LeClercq Trustee Dan Corbétt Trustee Justin Redfield Trustee Jeanne Allen Trustee Lou Hacker Trustee Brandon Coats President Guy Zambetti	Ayes	Nays	Absent	<u>Abstain</u>	gi T
OF CILE	DAY OF J	Ing Fig. (1) lage President,	Guy Zambetti		



3 May 2021 Zach Ruemelin Village of Gilberts, IL 60136 zruemelin@villageofgilberts.com

Re: Service Quote #21-0503-01

Mr. Ruemelin,

WaterSurplus is offering site services for an emergency completion of resin and gravel replacement to restore the Village of Gilberts Water Treatment Facility Softener #3 to near design criteria. The scope of services offered in this quotation include supervision and labor for replacement of all the media in one pressure filter vessel and inspect all 48 diffuser plates. WaterSurplus will refill and condition the new media and assist the village with sanitizing during initial regeneration. WaterSurplus will provide an experienced and qualified service engineer for the duration of the project. WaterSurplus will have on hand enough diffuser plates to replace all that may be damaged and will bill separately for any that are used.

Thank you for the opportunity to offer these services to the Village of Gilberts. Please feel free to contact WaterSurplus if you have any questions or comments on this information.

Regards,

Tim Hackbarth

TIM HACKBARTH

SENIOR FIELD SERVICE TECHNICIAN

C: 920-579-1274



Direct 815.240.3713 | Office 815.636.8833 | Email thackbarth@watersurplus.com 726 Beacon Street, Loves Park, IL 61111 | watersurplus.com



LABOR AND TOOLS

During the resin replacement, personnel will use WaterSurplus provided tools, ladders, or scaffold, as necessary. Old/used media shall be disposed of by the Village of Gilberts. Workers will try to keep dust and dirt to a minimum but will not be responsible for accidental damages to non-essential equipment in or near the water treatment facility. The village will be expected to provide an operator and forklift during the loading of medias as needed. The village will need to supply 2 1/2" fire hose long enough to get to the overhead door access, with a minimum of 40 psi and 40 gpm available.

11 MEDIA AND CONSUMABLES

WaterSurplus will install 320 cuft of cation resin and 90 cuft of gravel to one vessel. WaterSurplus will provide assistance to the village for sanitizing and conditioning the new media. 320 cuft of Cation Exchange Resin and 90 cuft of replacement gravel will be shipped in bags wrapped on pallets to the site by WaterSurplus. The village will be expected to unload the pallets when they arrive and store them in a safe area. Media will be shipped approximately 7. business days before the start of the project.

III. PRICING

Labor, expenses, and tools:

\$8,909.50

Medias, Gasket and Consumables:

\$25,995.50

Total Not To Exceed: \$34,905.00

^{*} Any diffusers replaced will be billed separately at a rate of \$96.75 each, installed *



IV. NOTES & CLARIFICATIONS

- · Consumables and expendables that have not been previously mentioned are not included in this scope and shall be provided under a separate contract, or by others.
- Clear Access The client shall provide clear and safe access to all equipment and components as required to complete the service request. Labor and materials needed to gain clear and safe access shall be by the client.
- Vac Services are provided by others and are not subcontracted through WaterSurplus.
- Disposal The client shall be responsible for the disposal of old resin, gravel, pallets, and trash generated from resin and gravel re-bedding.
- Water Testing The client shall be responsible for all water and lab testing, including Bac-T sampling/testing.
- Schedule The schedule for completion of the project is based on the assumption that all equipment, materials, chemicals and utilities are readily available for the noted service tasks. Client is responsible for a double regeneration of the vessel to be exchanged prior to the start of work.
- WaterSurplus does not offer or imply any guarantee or warranty on filter performance, operation, or existing parts or valves.
- Standard Business Hours Quoted costs are based on work and travel being completed during standard business hours of Monday-Friday between 7:00AM-5:00PM, excluding Holidays.
- This quote is valid for 30 days. Pricing is valid for a one-year period starting at receipt of order.

V. TERMS

- An invoice shall be issued by WaterSurplus after the services are completed.
- Payment terms are net 30 days from date of invoice.

VI. WARRANTY

No warranty is offered for these services.

VII. SCHEDULE

Date and Time is To Be Determined. Contact **Kevin Treptow** to schedule.

Email: Ktreptow@watersurplus.com

Office: 815-636-8833 or 800-919-0888 ext. 709

Direct: 815-240-3709

Midwest Power Vac

P.O. Box 728 Antioch, IL. 60002

Estimate

Date	Estimate No.
05/21/2021	21-192247

Name/Address

Village of Gilberts 87 Galligan Road Gilberts, IL. 60136 Project

Village of Gilberts 320 Raymond Drive Gilberts, IL 60136

Description

Fresh Water Filtration Tank

114"diameter X 67-3/4" deep Media resin sand and gravel = 14.56 cu yards or approximately 21.75 Tons 17 CUBIC YARDS REMOVED

One tank:

Travel to & from site (1.25 each way) = \$650.00
5027 Vacuum truck and labor prevailing wage = \$1.973.25
Set up and take down = \$143.00
TOTAL FOR ABOVE = \$2,766.25
Disposal hauling dumpsters lines not included a

Disposal, hauling, dumpsters, liner not included of materials removed. To be done by plant

Note: If needing this service:

(Disposal, hauling to landfill, dumpsters, and liner would be of \$834.00 if needed

8473950227	mwpowervac@gmail.com		
Phone #	E-mail		