

VILLAGE OF GILBERTS

RESOLUTION 08-2019

A RESOLUTION APPROVING THE PURCHASE OF A LIFT STATION PUMP FROM XYLEM COMPANY IN AN AMOUNT NOT-TO-EXCEED \$13,000

WHEREAS, the Village of Gilberts ("Village") operates a Wastewater Treatment Plant and several lift stations; and

WHEREAS, the Village has budgeted for the maintenance and replacement of lift station pumps; and

WHEREAS, the Village solicited quotes for the purchase of a replacement lift station pump at the Meadows Lift Station with Xylem Company providing the lowest responsible price;

THEREFORE, BE IT RESOLVED BY THE PRESIDENT AND BOARD OF TRUSTEES OF THE VILLAGE OF GILBERTS, ILLINOIS, as follows:

Section 1. Recitals. The recitals set forth above are hereby incorporated into and made a part of this Resolution as though set forth in this Section 1.

Section 2. Approval; Authorization. The Village Board of Trustees hereby authorizes the Village Administrator to execute the necessary documents to facilitate the purchase of a replacement lift station pump for the Meadows Lift Station from Xylem Company in an amount not to exceed \$13,000.

Section 3. Effective Date. This Resolution shall be in full force and effect after its approval in the manner provided by law.

PASSED BY VOTE OF THE BOARD OF TRUSTEES of the Village of Gilberts, Kane County, Illinois, this 23 day of April 2019.

	<u>Ayes</u>	<u>Nays</u>	<u>Absent</u>	<u>Abstain</u>
Trustee Dan Corbett	✓	_____	_____	_____
Trustee Elissa Kojzarek	✓	_____	_____	_____
Trustee Nancy Farrell	✓	_____	_____	_____
Trustee Jeanne Allen	✓	_____	_____	_____
Trustee Lou Hacker	_____	_____	✓	_____
Trustee Guy Zambetti	_____	_____	✓	_____
President Rick Zirk	_____	_____	_____	_____

APPROVED THIS 23 DAY OF April, 2019





Village President, Rick Zirk



Village Clerk, Courtney Nicholas



**Xylem Water Solutions USA, Inc.
Flygt Products**

April 5, 2019

9661 194th Street
Mokena, IL 60448
Tel (708) 342-0484
Fax (708) 342-0491

VILLAGE OF GILBERTS
87 GALLIGAN RD
GILBERTS, IL 60136

Quote # 2019-CHI-0258 Alternate 1, Version 2
Re: Gilberts – CP3140 pump upgrade – 15HP NP 3153

Attn: John Castillo, Utilities Superintendent

Hello John,

Xylem Water Solutions USA, Flygt Products Group Inc. is pleased to provide a quote for the following Flygt Pumping equipment.

This new generation Flygt 4" NP-3153 15hp Pump replaced the old CP-3140 a few years ago. This new #3153 version is much improved and has the Flygt N-Hydraulic Hard Iron Impeller which gives superior wear and non-clog solids handling. This new Pump will fit directly and slide right down onto the existing 2" Guide Rails and 4" Base Elbow.

We will notify you of pump arrival in Mokena, so that someone from Gilberts may pick up. Freight charges have been removed. Current stock will allow delivery within 2 weeks from order. Availability is subject to change.

Block 1

Qty	Part Number	Description
1	3153.095-0053	Flygt Model NP-3153.095 4" volute Submersible pump equipped with a 230 Volt / 3 phase / 60 Hz 15 HP 1750 RPM motor, 464 impeller, 1 x 50 Ft. length of SUBCAB 4G10+S(2x0,5) submersible cable, FLS leakage detector, volute is prepared for Flush Valve

Total Project Price \$ 12,338.90

Terms & Conditions

This order is subject to the Standard Terms and Conditions of Sale – Xylem Americas effective on the date the order is accepted which terms are available at <http://www.xyleminc.com/en-us/Pages/terms-conditions-of-sale.aspx> and incorporated herein by reference and made a part of the agreement between the parties.

Purchase Orders: Please make purchase orders out to: Xylem Water Solutions USA, Inc.

Freight Terms: 3 DAP - Delivered At Place 08 - Jobsite (per IncoTerms 2010)

See Freight Payment (Delivery Terms) below.

Taxes: State, local and other applicable taxes are not included in this quotation.



Back Charges: Buyer shall not make purchases nor shall Buyer incur any labor that would result in a back charge to Seller without prior written consent of an authorized employee of Seller.

Shortages: Xylem will not be responsible for apparent shipment shortages or damages incurred in shipment that are not reported within two weeks from delivery to the jobsite. Damages should be noted on the receiving slip and the truck driver advised of the damages. Please contact our office as soon as possible to report damages or shortages so that replacement items can be shipped and the appropriate claims made.

Taxes: State, local and other applicable taxes are not included in this quotation.

Terms of delivery: PP/Add Order Position

Terms of payment: Net 60 Days

Validity: This Quote will expire in ninety (90) days unless extended in writing by Xylem Water Solutions USA, Inc.

Customer Acceptance: A signed facsimile copy of this quote is acceptable as a binding contract.

Signature: _____ Company/Utility: _____

Name : _____ Address: _____
(PLEASE PRINT)

Email: _____

Date: _____ Phone _____

PO#: _____ Fax: _____

Schedule: Please consult your local Flygt Branch Office to get fabrication and delivery lead times.

Thank you for the opportunity to provide this quotation. Please contact me if there are any further questions.

Sincerely,



Jeff Garretson
Sales Representative
Phone: (708) 781-0172
Cell: (312) 343-6511
jeff.garretson@xyleminc.com

